

# SAMPLE SPECIFICATIONS ON DRAWINGS

©2008 Focus Collaborative, Inc.

Specifications, Quality Assurance, Inspections & Investigations for Your Construction Projects

156 Prospect Avenue  
Lansdale, PA 19446  
215.412.0601

2231 Route 50  
P.O. Box 248  
Tuckahoe, NJ 08250  
609.628.2390

## SUBMITTALS

Upon Request from the Architect, submit product data and samples on manufacturers as listed in the specifications, or as approved by Architect.

## MANUFACTURER'S LISTING

Submit a complete list, by specification article name, of all manufacturers and product types provided. If the Contractor makes a substitution, the submitted manufacturer's product data and samples must be approved by the Architect.

## GYPSUM BOARD ASSEMBLIES

Manufacturers: United States Gypsum Company, National Gypsum, Georgia Pacific, Lafarge North America.  
Gypsum Board Materials: ASTM C1396/C1396M. Thickness and types indicated, ends square cut, tapered edges.  
Accessories: Edge Trim: U shaped exposed reveal bead, as recommended by gypsum board manufacturer.  
Joint Materials: Reinforcing tape, joint compound and water; glass coated fiber tape for backing board.  
Fasteners: ASTM C1002 Type S12 hardened screws for gypsum board and corner beads.  
Adhesive: As recommended by gypsum board manufacturer.  
Install gypsum board over wood studs and joists, walls and ceilings in accordance with manufacturer's instructions and as detailed.

## CERAMIC TILE

Ceramic Tile Manufacturers: American Olean, Dal Tile, or Crossville Ceramics, Summitville Tile.  
Ceramic Tile Materials: Floor tile ANSI A137.1; wall tile ANSI A137.1; sizes as indicated. Colors and patterns selected by Owner.  
Mortar and Grout Manufacturers: Mapei Corporation. Custom Building Products or Laticrete International Inc.  
Mortar and Grout Materials: Mortar Materials: ANSI A118.4; Portland cement, sand, latex additive, and water.  
Grout: Cementitious type with latex additive.  
Install tile, mortar and grout in accordance with TCNA Handbook for Ceramic Tile Installation; and tile manufacturer's instructions.

## RESILIENT TILE FLOORING AND BASE

Manufacturers: Armstrong World Industries, Inc., Azrock by Tarkett, or Mannington.  
Submit color and finish samples for VCT and vinyl base.  
Vinyl Composition Tile: ASTM F1066 Class 2, through pattern; color and patterns as selected. Thickness: 1/8 inch (3 mm). Size: 12 x12 inch (300 x 300 mm).  
Vinyl Base: ASTM F1861; Type TV - thermoplastic vinyl; top set coved, 4 inch (100 mm) high, 1/8 inch (3 mm) thick, colors as selected. Premolded end stops and external corners, of same material, size, and color as base.  
Accessories: Subfloor Filler: White premix latex. Primers and Adhesives: Type recommended by manufacturer.  
Moldings and Edge Strips: Same material as flooring, profile to suit flooring material transitions.  
Install resilient flooring in accordance with the manufacturer's instructions.

**END OF SPECIFICATION**